

CITY OF NEWTON, MASSACHUSETTS

PURCHASING DEPARTMENT

purchasing@newtonma.gov

Fax (617) 796-1227

February 18, 2009

ADDENDUM #1

INVITATION FOR BID #09-61 & 09-62

ANNUAL - S & D BRASS FITTINGS & VALVES

ANNUAL – S & D WATER DISTRIBUTION FITTINGS & VALVES

THIS ADDENDUM IS TO: **Answer the following Questions:**

Q1. I was wondering if your bid #'s 09-61 and 09-62 were going to be awarded to one bidder for all items or if they were going to be line itemed out?

A1. Please reference paragraph 4 and 5, respectfully, of the the “Invitation for Bid” page (#2) of the original contract documents of each bid.

Q2. I was wondering if all fittings needed to be of Domestic manufacturer?

A2. They must meet AWWA Standard 509

Q3. I would like clarification on the following items on this bid. Are items 41 through 49 Ductile iron mechanical joint tapping sleeves or Stainless Steel Tapping Sleeves with a Carbon Steel Mechanical Joint outlet?

A3. Stainless Steel Tapping Sleeves with a Carbon Steel Mechanical Joint outlet

Q4. Do items # 30 – 32 have to have gaskets and bolts included?

A4. Yes

All other terms and conditions of this bid remain unchanged

PLEASE ENSURE THAT YOU ACKNOWLEDGE THIS ADDENDUM ON YOUR BID FORM

Thank you.

Re Cappoli

Chief Procurement Officer